



Office of Executive Engineer , Khand Karyalay
Up Jal Nigam (Rural) ,Mihauli , Auraiya

Issue No. : 00

Issue Date: 17.10.2024

Revision No.:-00

Revision Date :00

Test Report Water

Report No.	AUR/2025/05/14	Date	14/05/2025	Page No	01
Customer Details					
Office Name & Address	Genius Global Public School, Auraiya.				
Ref. Letter No. & Date	--				
Basic Details of Sample					
District	Auraiya	Block	Auraiya		
Gram Panchayat	Auraiya	Village/City	Autaiya		
Habitation	Auraiya	Location	Dibiyapur,bypass, Auraiya		
Water Source	Submersible Pump	Sample No	Aur/14/05/25		
Quantity of Sample	2 let	Date of S.C	13/05/2025		
Receiving Date	13/05/2025	S. Collector	Mr. Rishabh Chaubey		
Sample Depositor	Mr. Rishabh Chaubey		Analysis Completion Date		
Analysis Start Date	13/05/2025			14/05/2025	
Environmental Condition					
Temperature	25±3°C	Humidity	50±15%		
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Taste	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 1984
2	Odour	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2018
3	Colour	10	5	15	IS 3025 (Part 4): 1983(Platinum Cobalt Visual Comparison Method)
4	Turbidity (NTU)	1.01	1	5	IS3025(Part-10) :2023 (Nephelometric method)
5	PH	7.33	6.5	8.5	IS3025(Part11) :2022 (Electrometric Method)
6	TDS (Mg/L)	294	500	2000	IS3025 (Part 16) :2023 Gravimetric Method
7	Alkalinity (Mg/L)	216	200	600	IS3025(Part-23) :2023 (Titration Method)
8	Total Hardness (Mg/L)	260	200	600	IS3025(Part-21) :2019 (Titration Method)
9	Free Residual Chlorine	-	0.0	1	IS 3025(Part 26): 1986
10	Conductivity	-	NA	NA	IS 3025(Part 14): 2013
11	Sulphate (Mg/L)	28.42	200	400	APHA 23 RD Ed 2017, 4500-SO4 (E. Turbidimetric Method)
12	Nitrate (Mg/L)	12.18	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO3 (B. Ultraviolet Spectrophotometric Screening Method)
13	Fluoride (Mg/L)	0.628	1.0	No Relaxation	APHA 23 RD Ed 2017, 4500-F (C. Ion Selection Electrode Method)
14	Iron Mg/L)	0.28	1.0	No Relaxation	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method)
15	Chloride Mg/L)	42	250	1000	IS3025(Part-32) : 1988 (Titration Method)
16	Calcium (as Mg), Mg/l	120	75	200	IS 3025 (Part 40): 2019
17	Magnesium (as Mg), Mg/l	34.02	30	100	IS3025(Part-46) : 2023
*These Parameters are out of NABL Scope, BDL- Below Detection Limit, NT- Not Tested					
Note	1-This Certificate refers only to the particular sample (s) submitted for testing.				
	2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory				
	3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.				
	4-Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.				
	5-Parameters above permissible limit are written in Bold.				
Prepared by Atul Kumar Deputy Quality Technical Manager					
Authorized Signatory Amit Kumar Quality/ Technical Manager Quality Manager					
Laboratory Contact Details Email-					
Mob-					

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 20/12/2024

It is certified that an inspection team headed by Ram Akshay Ashray Kamal

(Name of Officers with designation) from Adhisasi Adhikari PHED

inspected the Genius Global Public School, Auraiya

(Name & Address of the school) on 20/12/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. AVR/2025/05/14 dated 14/05/2025

of U.P. Tal. Nigam (Rural), Mihauli (PHED Lab) certified that the

Genius Global Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 3 yrs (21/12/24 to 20/12/27)

Signature with Seal: RAM ASHRAY KAMAL

Name : अधिसासी अधिकारी

Designation : तहसील पालिका परिषद - औरैया

Name & Address of the Office / Department :

To Genius Global Public School
Dibiyapur Bypass Road, Auraiya
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

SAFE DRINKING WATER AND SAINTARY CONDITION CERTIFICATE

No. 011/2024-25/

Dated 20/12/24

It is certified that an inspection team headed by Ram Ashray Kamal

(Name of Officer with designation) from Adhisasi Adhikari

PHED inspected the Genius Global Public School, Auraiya

on 20/12/24 and on the basis of Water Test Report (Attached) bearing no AUR/
2025/05/14 date 14/05/2025 of U.P. Tal. Nigam (Rural), Mithauli (PHED Lab)


certified that the Genius Global Public School has

safe drinking water facilities for the students and members of staff of the

institution. School is also maintain the hygienic sanitation condition in the school

building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 3 yrs


20/12/24

Name RAM ASHRAY KAMAL

अधिशायी अधिकारी

Designation नगर पालिका परिषद-औरैया

To

Genius Global Public School

Dehriyapur Bypass Road, Auraiya



Office of Executive Engineer , Khand Karyalay
Up Jal Nigam (Rural) ,Mihauli , Auraiya

Issue No. : 00

Issue Date: 17.10.2024

Revision No.: -00

Revision Date :00

Test Report Water

Report No.	AUR/2025/05/14	Date	14/05/2025	Page No	01
Customer Details					
Office Name & Address	Genius Global Public School, Auraiya.				
Ref. Letter No. & Date	--				
Basic Details of Sample					
District	Auraiya	Block	Auraiya		
Gram Panchayat	Auraiya	Village/City	Autaiya		
Habitation	Auraiya	Location	Dibiyapur, bypass, Auraiya		
Water Source	Submersible Pump	Sample No	Aur/14/05/25		
Quantity of Sample	2 let	Date of S.C	13/05/2025		
Receiving Date	13/05/2025	S. Collector	Mr. Rishabh Chaubey		
Sample Depositor	Mr. Rishabh Chaubey				
Analysis Start Date	13/05/2025	Analysis Completion Date	14/05/2025		
Environmental Condition					
Temperature	25±3°C	Humidity	50±15%		
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Taste	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 1984
2	Odour	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2018
3	Colour	10	5	15	IS 3025 (Part 4): 1983(Platinum Cobalt Visual Comparison Method)
4	Turbidity (NTU)	1.01	1	5	IS3025(Part-10) :2023 (Nephelometric method)
5	PH	7.33	6.5	8.5	IS3025(Part11) :2022 (Electrometric Method)
6	TDS (Mg/L)	294	500	2000	IS3025 (Part 16):2023 Gravimetric Method
7	Alkalinity (Mg/L)	216	200	600	IS3025(Part-23) :2023 (Titration Method)
8	Total Hardness (Mg/L)	260	200	600	IS3025(Part-21) :2019 (Titration Method)
9	Free Residual Chlorine	-	0.0	1	IS 3025(Part 26): 1986
10	Conductivity	-	NA	NA	IS 3025(Part 14): 2013
11	Sulphate (Mg/L)	28.42	200	400	APHA 23 RD Ed 2017, 4500-SO4 (E. Turbidimetric Method)
12	Nitrate (Mg/L)	12.18	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO3 (B. Ultraviolet Spectrophotometric Screening Method)
13	Fluoride (Mg/L)	0.628	1.0	No Relaxation	APHA 23 RD Ed 2017, 4500-F (C. Ion Selection Electrode Method)
14	Iron Mg/L)	0.28	1.0	No Relaxation	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method)
15	Chloride Mg/L)	42	250	1000	IS3025(Part-32) : 1988 (Titration Method)
16	Calcium (as Mg), Mg/l	120	75	200	IS 3025 (Part 40) : 2019
17	Magnesium (as Mg), Mg/l	34.02	30	100	IS3025(Part-46) : 2023
*These Parameters are out of NABL Scope, BDL- Below Detection Limit, NT- Not Tested					
Note	1-This Certificate refers only to the particular sample (s) submitted for testing.				
	2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory				
	3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.				
	4-Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.				
	5-Parameters above permissible limit are written in Bold.				
Prepared by	Atul Kharar				
Deputy Quality/Technical Manager	Deputy Quality/Technical Manager				
Laboratory Contact Details Email-	Mob-				